

Montclair Board of Education
 Drinking Fountain Survey 2016 - 2017 School Year
 Buzz Aldrin Middle School

Location	Type	Test by Township of Mtc - Date	Test by Township of Mtc - Results	Detail Associates Test Date	Detail Associates Test Results	Detail Associates Test Date	Detail Associates Test Results	Detail Associates Test Date	Detail Associates Test Results	Detail Associates Test Date	Detail Associates Test Results	Comments
Hallway 2nd floor by Room 202	Drinkin Fountain			8/8/16	None Detected							
Hallway 2nd floor by Room 202	Drinkin Fountain									12/28/16	BDL	
Hallway 2nd floor by Room 208	Drinkin Fountain			8/8/16	None Detected							
Hallway 2nd floor by Room 210	Drinkin Fountain			8/8/16	None Detected							
Hallway 1st floor by Room 108	Drinkin Fountain			8/8/16	None Detected							
Hallway 1st floor by Room 110	Drinkin Fountain			8/8/16	None Detected							
Gym Floor	Drinkin Fountain			8/8/16	None Detected							
Nurse Office	Sink							11/16/16	BDL			
Basement next to cafeteria	Drinkin Fountain	3/11/16	<2 ug/L									
Hallway 1st floor by Office	Drinkin Fountain	3/11/16	<2 ug/L									
Kitchen	Sink	3/11/16	<2 ug/L									
Basement Girls Locker Room	Drinkin Fountain			8/8/16	2 ppb	10/14/16	<3 ppb					
Teachers Room	Sink									5/17/17	BDL	
Hallway 1st floor by Office	Drinkin Fountain					10/14/16	<3 ppb					

Footnote: BDL refers to Below detectable limits.